

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 381

Date : 15/09/2026

It is certified that an inspection team headed by Aabid Balkhi
(JEN PHED) (Name of Officers
with designation) from Public Health Engineering Department (Name of
Department/Office) inspected the St. Paul's School,
NEAR Shiv Mandir, Kuchaman City (Name & Address of
the School) on 15/09/2026 and found that the St. Paul's
School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year

Signature with Seal : [Signature]
Name : P.H.E.D S.Dn. K. City
Designation : Aabid Balkhi
JEN, PHED

To
St. Paul's School,
Kuchaman City

Junior Engineer
P.H.E.D S.Dn. K. City

(Name & Address of the Institution)

[Signature]
Principal
St. Paul's School
Kuchaman City
School Code :- 10760
Affiliation No :- 1730415

4 Member/Manager
Kable Multipurpose Education Society



OFFICE OF THE JUNIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY NAGOUR
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

Dated : 14.09.26

No. Lab/Tech(Bact)/2026-2027/ 381

To

ST PAUL'S SCHOOL
DIDWANA ROAD NEAR TEHSIL OFFICE
KUCHAMAN CITY

District: DIDWANA
Tehsil: KUCHAMAN CITY


Reference : Your Letter No.0
Date of Receipt : 08.09.2026

Name of Sample Taker:
SCHOOL STAFF

Lab Sample No.	Date & Time of Collection	Date of Exam.	Village/Town/ City	Source & Location	Residual Chlorine (mg/L)	Total Coli Form Organism/100 ml.	E-Coli Organism/100 ml.	Remark
679	08.09.2026	10.09.2026	DIDWANA ROAD NEAR TEHSIL OFFICE, KUCHAMAN CITY	R.O.-ST PAUL'S SCHOOL	NIL	NIL	-	Satisfactory


Junior Chemist
PHED Lab., Nagaur




Principal
St. Paul's School
Kuchaman City
School Code :- 10760
Affiliation No :- 1730415


Member/Manager
Noble Multipurpose Education Society

OFFICE OF THE JUNIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY NAGOUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Chem)/2026-2027/ 380

Dated : 14.09.26

ST PAUL'S SCHOOL
DIDWANA ROAD NEAR TEHSIL OFFICE
KUCHAMAN CITY

District: **DIDWANA**
Tehsil: **KUCHAMAN CITY**

Reference : 0

Dated: 08.09.2026

Date of Receipt : 08.09.2026

Name of Sample Taker. SCHOOL STAFF

Source		Bureau of Indian Standard (BIS) Drinking Water Standard (IS: 10500; 1991)	Maximum Desirable Limit	Maximum Permissible Limit	R.O.
Source Location					ST PAUL'S SCHOOL
Village/Town/ City					DIDWANA ROAD NEAR TEHSIL OFFICE KUCHAMAN CITY
Habitation					KUCHAMAN CITY
Date of Collection					08.09.2026
Date of Examination					09.08.2026
Lab. Sample No.					489

Note : - All results except pH are in mg/L.

1	pH	6.5 - 8.5	7.21
2	Turbidity (NTU)	5	10
3	Temperature (°C)	-	-
4	Colour (Hazen Units)	Unobjectionable	NIL
5	Odour	Unobjectionable	NIL
6	Total Alkalinity (as CaCO ₃)	200	600
7	Total Hardness (as CaCO ₃)	300	600
8	Calcium Hardness (as as CaCO ₃)	188	500
9	Magnesium Hardness (as as CaCO ₃)	125	417
10	Chloride (as Cl ⁻)	250	1000
11	Sulphate (as SO ₄ ⁻²)	200	400
13	Nitrates (as NO ₃ ⁻)	45	100
14	Fluoride (as F ⁻)	1.0	1.5
15	Total Dissolved Solids	500	2000
16	Residual Chlorine	-	-

Bold Italic Value indicates above Maximum Desirable Limit

Sample Not Collected by Laboratory

Not For Legal Purpose

[Signature]

Junior Chemist

PHED Lab Nagaur

Dated: 14.09.26



[Signature]
Principal
St. Paul's School
Kuchaman City
School Code :- 10760
Affiliation No :- 1730415

[Signature]
Member/Manager
Noble Multipurpose Education Society